

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Bayonne Head Start
21 West 8th Street
Bayonne, NJ
Phone:

Inspection Address: 21 West 8th Street
Bayonne, NJ

Inspection date: April 26, 2022

Water Outlet Tested:	1 st floor / Kitchen / Hand washing sink /	Failed
	1 st floor / Kitchen / Left sink	Pass
	1 st floor / Kitchen / Right sink	Pass
	1 st floor / Social Services / Left sink	Pass
	1 st floor / Classroom 1 / Left sink	Pass
	1 st floor / Classroom 2 / Left sink	Pass
	1 st floor / Classroom 3 / Left sink	Pass
	2 nd floor / Classroom 5 / Left sink	Pass
	2 nd floor / Classroom 5 / Left sink	Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB


Certification: Drinking water meets EPA Standards
See reports from (*Environmental Hazard Services, LLC.*)

Comment: Hand washing sink is not used for drinking or cooking. Tested because it is in Kitchen.

Operator License: **00121-E**



G. Luke Schroeder
NJ dept of Health ID# 001537



BAYONNE HEAD START

Center One 21 West 8th Street, Bayonne, N.J. 07002 (201)437-7702
Center Two 557 Kennedy Blvd., Bayonne, N.J. 07002 (201)437-2209
Center Three 7 West 9th St., Bayonne, N.J. 07002 (201)823-8880
Mailing Address: P.O. Box 1032, Bayonne, N.J. 07002

May 3, 2022

Attention All Parents and Guardians,

The Bayonne Head Start located at 21 W. 8th Street in Bayonne, N.J. has recently completed testing for lead and copper in the water. One sink in the kitchen has a lead level that exceeded .15ug/L.

This sink is only used for hand washing. It is not used for cooking or for drinking. A sign is posted above the sink that says Hand Washing Only. The children do not have access to the kitchen.

Sincerely,
Rosemary Simnowitz
Head Start Director

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Bayonne Head Start
557 Kennedy Blvd.
Bayonne, NJ 07002
Phone:

Inspection Address: 557 Kennedy Blvd.
Bayonne, NJ 07002


Inspection date: April 27, 2022

Water Outlet Tested:	1 st floor / 1 st bath / Sink	Pass
	1 st floor / Kitchen / Sink	Pass
	1 st floor / Classroom / Water fountain	Pass
	1 st floor / 2 nd bath / Sink	Pass
	2 nd floor / 1 st bath / Sink	Pass
	2 nd floor / 2 nd bath / Sink	Pass
	2 nd floor / Classroom / Water fountain	Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from (*Environmental Hazard Services, LLC.*)

Operator License: 00121-E



G. Luke Schroeder
NJ dept of Health ID# 001537