

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits
Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Bayonne Head Start
21 West 8th Street
Bayonne, NJ 07002
Phone:

Inspection Address: 21 West 8th Street
Bayonne, NJ 07002


Inspection date: May 10, 2023

Water Outlet Tested:	1 st floor / Kitchen / Hand washing sink	Failed
	1 st floor / Kitchen / Left sink	Pass
	1 st floor / Kitchen / Right sink	Pass
	1 st floor / Social Service / Left sink	Pass
	1 st floor / Classroom #1 / Left sink	Pass
	1 st floor / Classroom #2 / Left sink	Pass
	1 st floor / Classroom #3 / Left sink	Pass
	2 nd floor / Classroom #4 / Left sink	Pass
	2 nd floor / Classroom #5 / Left sink	Pass


EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from (*Phoenix Environmental Laboratories, Inc.*)

Operator License: 00121-E



G. Luke Schroeder
NJ dept of Health ID# 001537



BAYONNE HEAD START

Center One 21 West 8th Street, Bayonne, N.J. 07002 (201)437-7702
Center Two 557 Kennedy Blvd., Bayonne, N.J. 07002 (201)437-2209
Center Three 7 West 9th St., Bayonne, N.J. 07002 (201)823-8880
Mailing Address: P.O. Box 1032, Bayonne, N.J. 07002

May 15, 2023

Dear Parents and Guardians,

The Bayonne Head Start located at 21 W. 8th Street in Bayonne, N.J. had its annual testing of the water for lead and copper completed on May 10, 2023.

One sink in the kitchen has a lead level that exceeded .15ug/L.

This sink is only used for hand washing by the kitchen staff. It is not used at all for cooking or for drinking.

There is a sign posted above the sink that says Hand Washing Only. The children do not have access to the kitchen.

Sincerely,

Rosemary Sinnowitz

Head Start Director

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Bayonne Head Start
557 Kennedy Blvd.
Bayonne, NJ 07002
Phone:

Inspection Address: 557 Kennedy Blvd.
Bayonne, NJ 07002

Inspection date: May 11, 2023

Water Outlet Tested:	1 st floor / 1 st Bath / Sink	Pass
	1 st floor / 2 nd bath / Sink	Pass
	1 st floor / Kitchen / Sink	Pass
	2 nd floor / 1 st bath / Sink	Pass
	2 nd floor / 2 nd bath / Sink	Pass
	2 nd floor / Classroom / Water fountain	Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from (*Phoenix Environmental Laboratories, Inc.*)

Operator License: 00121-E



G. Luke Schroeder
NJ dept of Health ID# 001537