



New Jersey Department of Health
Environmental and Chemical Laboratory Services
PO Box 361, Trenton, NJ 08625-0361
NJDEP Lab ID#: 11036
EPA Lab ID#: NJ01351

Client Address:
Bayonne HeadStart Center
21 W 8th Street
Bayonne NJ, 7002

Report Date: 07/27/2026 12:57
Project: Drinking Water Lead and Conner

Client Sample ID: **Kitchen Sink #1**
Sample Location:
Field ID No: Kitchen Sink #1
Sample Type: First Draw

Lab Number: 26G2104-01
Sampled: 7/14/2026 8:00:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	129		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:02	EPA 200.8
Lead	7.85		0.136	1.00	ug/L	07/24/2026	07/24/2026 14:02	EPA 200.8

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Kitchen Sink #2**
Sample Location:
Field ID No: Kitchen Sink #2
Sample Type: First Draw


Lab Number: 26G2104-02
Sampled: 7/14/2026 8:00:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	65.0		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:04	EPA 200.8
Lead	0.232	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:04	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Kitchen Sink #3**
Sample Location:
Field ID No: Kitchen Sink #3
Sample Type: First Draw


Lab Number: 26G2104-03
Sampled: 7/14/2026 8:00:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	56.3		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:05	EPA 200.8
Lead	0.287	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:05	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Kitchen Sink #4**
Sample Location:
Field ID No: Kitchen Sink #4
Sample Type: First Draw


Lab Number: 26G2104-04
Sampled: 7/14/2026 8:10:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	73.1		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:07	EPA 200.8
Lead	1.23		0.136	1.00	ug/L	07/24/2026	07/24/2026 14:07	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 1 - Sink #1**
Sample Location:
Field ID No: Class 1 - Sink #1
Sample Type: First Draw


Lab Number: 26G2104-05
Sampled: 7/14/2026 8:10:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	40.2		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:08	EPA 200.8
Lead	0.422	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:08	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 1 - Sink #2**
Sample Location:
Field ID No: Class 1 - Sink #2
Sample Type: First Draw


Lab Number: 26G2104-06
Sampled: 7/14/2026 8:10:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	38.2		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:10	EPA 200.8
Lead	0.229	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:10	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 2 - Sink #1**
Sample Location:
Field ID No: Class 2 - Sink #1
Sample Type: First Draw


Lab Number: 26G2104-07
Sampled: 7/14/2026 8:15:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	80.0		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:11	EPA 200.8
Lead	0.758	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:11	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 2 - Sink #2**
Sample Location:
Field ID No: Class 2 - Sink #2
Sample Type: First Draw


Lab Number: 26G2104-08
Sampled: 7/14/2026 8:15:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	40.0		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:16	EPA 200.8
Lead	0.484	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:16	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 3 - Sink #1**
Sample Location:
Field ID No: Class 3 - Sink #1
Sample Type: First Draw


Lab Number: 26G2104-09
Sampled: 7/14/2026 8:15:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	37.5		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:18	EPA 200.8
Lead	0.598	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:18	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 3 - Sink #2**
Sample Location:
Field ID No: Class 3 - Sink #2
Sample Type: First Draw


Lab Number: 26G2104-10
Sampled: 7/14/2026 8:20:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	42.9		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:19	EPA 200.8
Lead	0.419	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:19	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 4 - Sink #1**
Sample Location:
Field ID No: Class 4 - Sink #1
Sample Type: First Draw


Lab Number: 26G2104-11
Sampled: 7/14/2026 8:20:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	43.9		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:21	EPA 200.8
Lead	0.261	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:21	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 4 - Sink #2**
Sample Location:
Field ID No: Class 4 - Sink #2
Sample Type: First Draw


Lab Number: 26G2104-12
Sampled: 7/14/2026 8:20:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	37.8		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:22	EPA 200.8
Lead	0.276	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:22	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 5 - Sink #1**
Sample Location:
Field ID No: Class 5 - Sink #1
Sample Type: First Draw


Lab Number: 26G2104-13
Sampled: 7/14/2026 8:25:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	38.6		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:24	EPA 200.8
Lead	0.340	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:24	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Class 5 - Sink #2**
Sample Location:
Field ID No: Class 5 - Sink #2
Sample Type: First Draw


Lab Number: 26G2104-14
Sampled: 7/14/2026 8:25:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	34.3		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:38	EPA 200.8
Lead	0.416	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:38	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Adult Bathroom - First Floor**
Sample Location:
Field ID No: Adult Bathroom - First Floor
Sample Type: First Draw


Lab Number: 26G2104-15
Sampled: 7/14/2026 8:25:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	70.6		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:39	EPA 200.8
Lead	0.490	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:39	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Office: First Floor - Sink #1**
Sample Location:
Field ID No: Office: First Floor - Sink #1
Sample Type: First Draw


Lab Number: 26G2104-16
Sampled: 7/14/2026 8:30:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	72.5		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:41	EPA 200.8
Lead	1.41		0.136	1.00	ug/L	07/24/2026	07/24/2026 14:41	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Office: First Floor - Sink #2**
Sample Location:
Field ID No: Office: First Floor - Sink #2
Sample Type: First Draw


Lab Number: 26G2104-17
Sampled: 7/14/2026 8:30:00AM
Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	56.8		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:42	EPA 200.8
Lead	0.612	JR	0.136	1.00	ug/L	07/24/2026	07/24/2026 14:42	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Adult Bathroom - Second Floor**

Sample Location:

Field ID No: Adult Bathroom - Second Floor

Sample Type: First Draw

Lab Number: 26G2104-18

Sampled: 7/14/2026 8:35:00AM

Received: 7/21/2026 10:58:00AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	81.9		0.243	0.500	ug/L	07/24/2026	07/24/2026 14:44	EPA 200.8
Lead	1.05		0.136	1.00	ug/L	07/24/2026	07/24/2026 14:44	EPA 200.8

Notes and definitions:


J Approximate Value
 JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor